



MUNICIPAL CORPORATION OF DELHI
(PUBLIC HEALTH DEPARTMENT: CIVIL LINES ZONE
16 RAJ PUR ROAD, DELHI – 110054

DHO/CLZ/2024/569

Dated: 18/6/24

SCHOOL HEALTH CERTIFICATE

NAME OF THE SCHOOL : M/S Sant Nirankari Public School
at Sant Nirankar Colony, Delhi 110009.

: No of Student : BOYS – 973, GIRLS- 657, TOTAL-1630

: No of Staff Members : 77

: Date of Inspection : 07.06.2024

- Rooms are having properly white washed, ventilated and having adequate lighting.
- Drinking water: Delhi Jal Board-Water supply with RO fitted water coolers are installed at each floor for student.

- No of Class Rooms : 62

- No of Toilets : Boys- 16, Girls- 15, Total- 31

- No of urinals : 19

Sanitation & Hygiene : General sanitation and hygiene are properly maintained in the school and is satisfactory from Health point of view.

In view of the above submissions this health certificate is being issued in favor of the school by undersigned, after being fully satisfied and having **NO OBJECTION FROM HEALTH POINT OF VIEW.**

The above certificate is valid for one year from date of issue.


Dy. Health Officer
Civil Lines Zone

Deputy Health Officer
Civil Lines Zone
Municipal Corporation of Delhi
16, Rajpur Road, Delhi-110054

Manager
Smt. Ranjana Grover
M/S Sant Nirankari Public School
at Sant Nirankari Colony, Delhi 110009.



**DELHI JAL BOARD: GNCTD
ZONAL LABORATORY WTP WAZIRABAD, DELHI-54**



TEST REPORT

Sample ID	Ref. No. D.J.B/DTQC/Wzd./2024-25/Paid-144-145		
Location /Address of Sample	Sant Nirankari Public School, Sant Nirankari Colony, Delhi-110009		
Letter Reference No.	SNPSNC/DJB/2024/002/1812	Ref. Letter Date	14.10.2024
Challan No.	176	Challan Date	16.10.2024
Sample Collection date	18.10.2024	Analysis start date	18.10.2024
Any other Information	--	Analysis end date	20.10.2024
		Reporting date	21.10.2024

TEST RESULTS

S.No	Parameters	Unit	As per the IS 10500		Inlet	Outlet
			Acceptable limit	Permissible limit		
1	Colour	CU	5 (Max)	15 (Max)	2.0	2.0
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	1	5	4.2	1.8
4	pH at 25 °C	--	6.5-8.5	No relaxation	7.35	7.07
5	Electrical Conductivity	µS/cm	-	-	591	128
6	Total Dissolved Solids	mg/L	500(Max)	2000(Max)	384	82
7	Total Alkalinity	mg/L	200(Max)	600(Max)	138	36
8	Total Hardness	mg/L	200(Max)	600(Max)	200	32
9	Calcium as Ca	mg/L	75(Max)	200(Max)	45	8
10	Magnesium as Mg	mg/L	30(Max)	100(Max)	21	3
11	Iron	mg/L	1.0(Max)	No relaxation	0.08	0.04
12	Chloride	mg/L	250(Max)	1000(Max)	68	18
13	Fluoride	mg/L	1.0(Max)	1.5(Max)	0.87	0.26
14	Ammonical-Nitrogen	mg/L	0.5(Max)	No relaxation	BDL	BDL
15	Nitrate	mg/L	45(Max)	No relaxation	3.8	1.5
16	Sulphate	mg/L	200(Max)	400(Max)	55	6.2
17	Residual Chlorine	mg/L	0.2 (Min.)	1.0(Max)	0.25	1.25
18	Coliform Count at 37° (MPN)	/100 mL	Absent	No relaxation	0	0

*BDL=Below Detection Limit

.....End of Report.....

Remarks: For the tested parameters the water samples conforms specification and can be considered for the drinking purpose.

Tested by
Lab.Tech.

Verified for Chemical parameters
Asstt. Chemist

Verified for MPN
Asstt. Bact.

Authorized by
Chemist /ACWA(WZD)

Asstt. Chief Water Analyst
D.J.B. (Govt. of N.C.T. of Delhi)
Water Works, Wazirabad